Certified National Analytic Labs
CNA
DRINKING WATER · NON-POTABLE WATER · MILK · FOOD · AIR

27 Kent Street, Suite 102
Ballston Spa, NY 12020

Client:
North Warren Central School
6110 State Route 8
Chestertown, NY 12817

Project:
North Warren Central School

CNA Environmental, LLC received the sample(s) associated with this batch in compliance with NYSDOH guidelines. The requested analysis methods and results are detailed in the following data summary reports. Any exceptions to method procedures are listed in the comments section below.

To meet the New York Sanitary Code for Public Drinking Water, Total Coliform must be absent or <1; all other analytes must be less than or equal to the MCL.

Metals:
Sample(s) meet the NYSDOH MCL criteria for the parameters shown in the results section.

Exceptions: N/A

Lab ID: C038587-01 **Date Collected:** 08/23/18 06:30 **Matrix:** Drinking Water

Sample ID: Elkay Water Cooler #NWWC001 **Date Received:** 08/23/18 14:50

Total Metals by EPA 200.9

Analyte	Results	Flag	Units	MDL	RL	Method	Analyzed	Prepared	MCL
Lead	ND	HT	mg/L		0.001	EPA 200.9	08/29/18 12:38	08/29/18	0.015

CNA Environmental, LLC

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jeremy C. Smith, Lab Manager/Deputy QA Officer